KEKB facilities and operation M. Yoshioka (KEKB Review@Feb.11,'03)

•Electricity

- Cooling water
- Air conditioning
- Building and tunnel
- Operation
- Upgrade to Super B

Electricity (1) TRISTAN facility is converted to KEKB

| Electric | power | consumption | (requ | irement) |
|-----------------|-------|-------------|-------|----------|
|-----------------|-------|-------------|-------|----------|

| 21.2 MW | (45.8%) |
|---------------|---|
| 16.2 MW (1 | Including P_{ref}) |
| 9.2 MW | (19.9%) |
| 8.8 MW | (19.0%) |
| 4.0 MW | (8.6%) |
| 3.1 MW | (6.7%) |
| 46.3 MW | (100%) |
| ~260 GWH | /year |
| | 16.2 MW (J 9.2 MW 8.8 MW 4.0 MW 3.1 MW 46.3 MW |

Electricity (2)

- Capacity of the KEK substation
 - 150 MW + 25 MW (154 kV) → Big enough
- Contract with Tokyo Electric Power Company Peak power
 82.74 MW
 - ~0.12% of TEPCO Max. capacity
- Discount

Summer season

8.4 ¢/kWh

- KEK total electricity, including Proton Synchrotron, Photon Factory and others 462 GWh/year
- Total rate

46.6 Oku-yen(38.9M \$)

- Average unit cost
- Margine of TEPCO electricity in March '03 becomes zero, due to the inspection for nuclear power plants

Electricity (3)

- Industrial Electricity General Price for Various
 Countries in 1997 (one example among many statistics)
- 100% Japan (KEK price; 8.4 ¢/kWh) \bigcirc (SLAC; ?) US ~30% 0 UK ~45% 0 (**DESY**; ?) Germany ~49% 0 (CERN; ?) France ~35% \bigcirc
- Substantial competition between electric power companies is needed to realize "A reasonable price"
 - Free electricity market will be extended in 2005

KEK substation



- Two main transformers 154 kV/66 kV
- 150 MW + 25 MW

Electricity (4) Trouble

- Accidents near to KEK \rightarrow Blackout for 3~4 sec
 - A few times/year

Wet snow in early spring Lightning in summer or fall Storm (Typhoon)

– Helium refrigerator stop : ~1 shift to recover

• <u>Accidents far from KEK</u> $\rightarrow \sim 10\%$ Voltage drop

• ~10 times/year

– Almost no damage

So far, no trouble in substation itself at KEK!

Cooling Water System TRISTAN facility is converted to KEKB

- Total power consumption
- Dry cooling tower
- Wet cooling tower
- Air conditioning, cooling fun

36 MW (77.8%)

46.3 MW

- 8 MW (17.2%)
- 2.3 MW (5%)
- System problems in dry cooling tower
 - Dry bulb temperature

25 °C (Design)

- » Poor Cooling in Summer
- Inconsistent between designed and real heat load in cooling tower for klystron-body and RF dummy loads (tower >> real heat load)
 - » Over cooling or freezing in winter (three times so far)

Dry Cooling tower

- Broken tower on the early morning of the Jan.15, 2003
- Heat load only 0.3 MW
- Capacity of cooling tower
 5 MW
- **→ Temp.** -7.8 °C
- Tower-head is frozen and burst up, but repaired quickly (~1 shift lost)





Air Conditioning TRISTAN facility is converted to KEKB


- 3km-long tunnel is devided into 16 air conditioning-zones
- Main heat source; power cables, air cooled corrector magnets and solenoid coils
- Other heat source; water-cooled main magnets and vacuum chambers
- Total; ~1.5 MW
- Supply and return air ducts are used in the tunnel
- **Temperature is set to 24°C at all seasons**
 - In winter, tunnel must be heated up when machine is turned off, to keep the temperature stable

Air conditioning (2) Temperature in the tunnel


- below: Temp. distribution 0 in the tunnel (17 hours)
- right: Temp. vs time 0


Y Max-Min Range Scale:

Feb. 6, 18:00~Feb. 7, 11:00 0 **(17 hours)**



Data Get Inter Conv






I He Edit Drenser Cache thannel Ast Wester

Air conditioning(3)




Supply and return air duct in the tunnel

Air conditioning (4)



Building and Tunnel

- Geology: Thick diluvial layers (>600 m)
 - Consisting of many layers of clayey or sandy soil and conglomerate clay
 - Rich underground water (pumping up 500~1000 ton/day for Proton Synchrotron cooling)
- Arc section (floor = GL 12m, on sandy soil layer)
 - direct foundation
- Experimental hall (floor = GL 16 m, on clayey soil layer which is not strong enough)
 - 25 m-long pile foundation to sandy soil layer
- Tunnel is divided into 60 blocks (~50 m-long each) and connected with "expansion joints" each other
 - Flexible joint (elastic)



Building and Tunnel (2)

 West and south arcs are sinking steadily by 1~2mm/year (maybe) due to pumping up of underground water


 Orbit length is affected by tunnel temperature, earth tide, atmospheric pressure, (probably) sunshine, and etc.

 Geology and tunnel are not so bad for B-Factory but feedback systems are needed

Operation of accelerator & facility

- Two different organizations
 - Accelerator Laboratory (98 staff for KEKB+Linac)
 - Plant & Facilities Department
 - KEK staff frequently transfer position(~3 years)
 - Few staff number (only 17 for machine and electricity)
- Two different companies (out-sourcing)
 - Accelerator: Mitsubishi Electric System and Service Corp.
 - 24 (KEKB+ Linac), 15 (Photon Factory)
 - Plant and Facilities; Takahashi Kogyo Corp. (50)
 - 32 (Machine), 18 (Electricity)
- Issues to be solved;
 - How to integrate know-how, experiences, · · · ·
 - How to secure close contact between two organizations

Control room for; Accelerator (left), Machine and Electricity (right)



Upgrade to Super B Key Issues from facility view point

- Increase beam current and RF power
 - New houses for RF sources
 - Number of klystrons 24(B) /56 (S-B)
 - Upgrade cooling water system for RF and vacuum chambers
 - **SR + HOM power 8** (B)/34 (S-B) MW
 - Rearrangement of cooling towers
 - Minor change of substations
 - Total wall-plag power 73 MW < TRISTAN
- Upgrade Injector Linac
 - Isolate from Photon Factory (very important)
 - New building for damping ring and etc.
 - Upgrade cooling water systems
- Study for effects about environment and/or geological stability (maybe) needed