

KEKB Review 2009

Upgrade of RF Power Source & Cooling System

KEK; M. Ono

2009-02-10

Super KEKB RF parameters; Base Line Design

Ring	LER	HER		unit
Beam energy	3.5	8.0		GeV
Beam current	9.4	4.1		A
Energy loss /turn	0.84	3.42		MV
Radiation loss	7.91	14.02		MW
Total loss factor, assumed	40 ± 5	45 ± 10		V/pC
Parasitic loss	7.09 ± 0.89	1.52 ± 0.34		MW
Total beam power	15.0 ± 0.9	15.5 ± 0.3		MW
Cavity type	ARES (modified)	ARES	SCC	
Number of cavities (= klystrons)	22~24	18~16	8	
Voltage /cavity	0.5	0.5	1.3	MV
Beam power /cavity	650	720	460	kW
Wall loss /cavity	233	150	-	kW
Detuning frequency	44	31	75	kHz
Klystron power	940	930	490	kW
Total RF voltage	~11	~18		MV
Total AC plug power	35	33		MW

Number of RF units(=Klystron #)

For Acceleration Cavity		KEKB		SuperKEKB	
		LER	HER	LER	HER
Oho	D4		3		12
	D5		4	8/12	4/0
Fuji	D7	5		8	
	D8	5		8	
Nikko	D10		4		4
	D11		4		4
Total		25		48	
For Crab Cavity		LER	HER	LER	HER
Nikko	D10				(1)
	D11	1	1	1	1
Total		2		2(+1)	

Share is not decided


If HER Crab added

High Power RF Source Distribution

Nikko:
**SCC(HER:4+4)
& Crab(HER:1(+1) / LER:1)**

Fuji:
ARES(LER:8+8)

Oho:
**ARES(HER:12+4(0)
/ LER:0+8(12))**



High Power RF-unit

Klystron : CW1.2 MW, 509MHz , Modulating Anode
Typical Ope. Condition for 1MW Output : >90kV, 17A

Wave Guide System : WG(WR1500), Circulator, Dummy Load

Water Cooling: Cooling of WG System and Klystron Body

Vapor Cooling: Cooling of Klystron Collector



Klystron Power Supply (KPS): A-Type (for 2 Klystrons);
Cathode(90kV, 40A), [Anode(+80kV, 10mA)/Heater(30V,28A) PS] x 2, Crowbar

Cavity: ARES, SCC, Crab

Every Components are quite Stably and Reliably operated.


But, almost every things are Old enough!

RF units: for ARES cavity(Fuji/Oho)



KEKB:

Kly Out ~ 600kW for two ARES





Super KEKB:

Kly Out > 900kW for one ARES

Not only increase # of Cavities, but also increase the Out put power of Klystron.



Comment on KPS; A-type is for two- & B-type is for one klystron.

RF units: for SCC/Crab cavity(Nikko)




KEKB:

Kly Out ~ 300kW for one SCC



Super KEBB:


Kly Out ~ 490kW for one SCC




If one more Crab will be added, need one more RF unit.

Layout of RF-unit is not changed, but increase the Out put power of Klystron.

Present D7 Klystron Gallery; 5-klystrons for LER




D7 Klystron Gallery; 8-klystrons for LER



Need Area Extension;
For RF-control & KPS


Reserved for
Kicker/Septum

Present D8 Klystron Gallery; 5-klystrons for LER



D8電源棟 (1/250)


D8 Klystron Gallery; 8-klystrons for LER



Need Area Extension;
For KPS


Reserved for
Kicker/Septum &
Beam Monitor

Present D4 Klystron Gallery;
3-klystrons for HER



D4電源棟 (1/250)


Reserved for Beam Monitor




Need Area Extension;
For Pump , RF control & KPS

D4 Klystron Gallery;
12-klystrons for HER


Present D5 Klystron Gallery; 4-klystrons for HER



D5電源棟 (1/250)



Need Area Extension;
For KPS
(need ground breaking for this area)




D5 Klystron Gallery;
12 (8)-klystrons for HER
& 0 (4)-klystrons for LER



To Change RF-unit Layout

Squeeze Space between the RF-unit;

- 1) Replace B-type KPS to A-type.
- 2) Rearrange Klystron Socket position & Vapor Suction Pipe position, & relevant cabling/piping.





Present Layout;
(D5-A & B)



SuperKEKB Layout

Conception of Vapor Cooling



Vapor Cooling; Modification

KEKB; One Vapor Cooling System(one Air-Fin-Cooler) / Gallery



----> SuperKEKB; Two Vapor Cooling Systems / Gallery
: Add 2nd Air-Fin-Cooler/ Vapor Suction Pipe


Comment on Operation;

The Idea is simple, but actual Operation is complicated for Parallel Vapor Cooling, because each Pressure are changed.

---> Good Vapor Conductance may be Key Issue.

---> Add one more system, even Cooling Power ~5-6MW/Air-Fin(in design).






*Two Klystrons Stand side by side;
(D7-A & B units).
In SuperKEKB, all stations will be
the similar Layout.*

*KPS: DC -90kV, 20A x 2
Suppression of the Corona Sparking,
lead to Stable Operation.
Eliminate almost all fake Crowbar Work.*







D4 Klystron Gallery

Present only 3 klystrons
---> 12 klystrons at SuperKEKB

Vapor/Water Separator



Connection Port;
Prepare at 1st phase

Strategy To Increase RF-unit;

1st phase: At the initial long shut down(~3years?);

- 0) Build the area/space for KPS & for RF-control.
- 1) Available RF-unit(include KPS) will be rearranged.
- 2) Prepare Vapor Suction Connection Ports & relevant Cabling/Piping.
- 3) Add Vapor Suction Pipe for 2nd Air-Fin-Cooler.

2nd-Nth phase: At the short shut down(~half years?);

- 1) Add RF-units; Cavity/ Klystron/ Wave Guide/ Cooling...
- 2) Add 2nd Air-Fin-Cooler ; if Kly# >5/Gallery.
- 3) N~3-5??; finish upgrade RF-source after N-years SuperKEKB Commissioning.

Infrastructure; Electricity

Power Station	Station total (MW)	Magnet (MW)	He-refrig. (MW)	RF (MW)	Utility (MW)	BT (MW)
Tsukuba (D1,D2)	4.6	1.4	0.4	0	2.8	
	8	1.5	0.5	2	4	
Oho (D4,D5)	8.8	2.2		4.9	1.7	
	41.2	2.2		36	3	
Fuji (D7,D8)	16.1	1.1		11.2	2.3	1.5
	29.6	1.1		24	3	1.5
Nikko (D10,D11)	14.8	3.8	2.5	6.2	2.3	
	16	3.8	2.5	6.7	3	

← KEKB
← Super KEKB

	Present KEKB 071121 (MW)	Super KEKB (MW)
B-Factory	44.3	94.8
KEK-total	63.6	~120


Need Power Up of the Power-Station (add Bank).

Infrastructure; Cooling Water

	Unit	Vacuum Chamber	ARES Cavity	ARES Home	Kly-Body, KPS, W.G.	Magnet	TOTAL
Disp. Power; SuperKEKB	MW	33.6	12	3	7.5	5.4	61.5
Cooling Water; SuperKEKB	L/min	31200	31150	4000	11200	15650	93200
					21900		21900
Cooling Water; Present KEKB	L/min	7200	10000		11200	15650	44050
					21900		21900

Comments;

- 1) *Cooling except Vapor-Cooling are listed.*
- 2) *Total Water-Flow of Facilities are listed.*
- 3) *Brown indicate Not Pure-water(~Tap Water quality).*
- 4) *Need(add) New Cooling Facility(include piping/AFC) for Vac/ARES ; 4 new facility buildings are needed.*
- 5) *Same(Present) ΔT are assumed for Flow-Rate estimation.*



4 New Facility Building;
at Arc sections.

1) Vacuum Chamber



Upgrade Present Facility;

2) ARES Cavity

3) ARES-HOM

4) Klystron/WG

Present Facility;

5) Magnet/Mag.PS



Power Balance; Check the Estimations

Injecting Electric Power ; ~95MW

$$94.8\text{MW} = 68.7(\text{RF}) + 8.6(\text{Mag}) + 3(\text{He-refrg}) + 1.5(\text{BT}) \\ + 13(\text{Utility})$$

Dissipating Heat Power ;


$$61.5(\text{Water; Vac \& ARES}) + \sim 24(\text{Vapor; Kly}) = \sim 86\text{MW}$$

Others(Utility);

Water Cooling Facility(Plate-Heat-Exchanger, Pump, Air-
Fin-Cooler), Air-Conditioner, ... ---> ~10MW

95MW <---> ~96MW : Consistent !?

Klystron Worked Time: (M.Yoshida; 08/12/25)




Conclusion

Based on the Present Design, Upgrading of the RF-Source & Relevant Infrastructure may be Feasible.

But, Huge Electric Power is needed; 95MW(120MW in KEK).

So, seek the possibilities,

- 1) Low intensity (low beta) machine design,
and also,*
- 2) Save/Recover Energy;
Generate Electricity by Vapor Heat Power;
~10% ?? CPD-Klystron; Collector Potential
Depression ; completely unknown its feasibility.
etc.*



CPD-Gyratron

エネルギー回収型ジャイロトロン概略図

従来効率 = $1000\text{kW} / 80\text{kV} / 40\text{A} = 31\%$

回収後効率 = $1000\text{kW} / 50\text{kV} / 40\text{A} = 50\%$

RF: 6.6kV AC Plug Power for Klystron

Kly. Gallery	Klystron #		AC Plug Power : 6.6kV				
	KEKB	Super KEBB	KEKB		Super KEBB		
			300A	150A	300A	150A	
For Acc. Cavity							
Fuji:D7	5	8	2	1	4		
Fuji:D8	5	8	2	1	4		
Oho:D4	3	12	2	1	6		
Oho:D5	4	12	2	1	6		
Nikko:D10	4	4	2		2		
Nikko:D11	4	4	2		2		
T0tal	25	48	12	4	24		
For Crab Cavity							
Nikko:D10		(1)				(1)	<i>If HER Crab added</i>
Nikko:D11	2	2		1		1	

Replace 150A(for B-type KPS) to 300A(for A-type) & Add new 300A power line.

LER: Klystron Power Supply

Upgrade KPS name	Present KPS type	1st Upgrade status	Comment	KPS method	Nth Upgrade status
D7-AB	A	A-old		90kV/20A x 2; IVR	
D7-CD	A	A-old		90kV/20A x 2; IVR	
D7-EF			New KPS/ Install to new Gallery	~95kV/20A x 2; Switching	A-new:1
D7-GH	B	A-old/(new)	Exchange to A-type; If old <--> D4-ED/ new if possible		(A-new:12)
D8-AB	A	A-old		90kV/20A x 2; IVR	
D8-CD	A	A-old		90kV/20A x 2; IVR	
D8-EF			New KPS/ Install to new Gallery	~95kV/20A x 2; Switching	A-new:2
D8-GH	B	A-old/(new)	Exchange to A-type; If old <--> D1-AB/ new if possible		(A-new:13)
			(below two KPS ; not decided for LER or HER)		
D5-IJ			New KPS/ Install to new Gallery; (if used for LER)	~95kV/20A x 2; Switching	A-new:3
D5-KL			New KPS/ Install to new Gallery; (if used for LER)	~95kV/20A x 2; Switching	A-new:4

HER: Klystron Power Supply

Upgrade KPS name	Present KPS type	1st Upgrade status	Comment	KPS method	Nth Upgrade status
D4-AB	A	A-old		90kV/20A x 2; IVR	
D4-CD	B	B(/A-new)	Exchange to new A-type; if possible		A-new:5
D4-EF	(A)		(Not used at 1st; move to D7-GH)	(90kV/20A x 2; IVR)	A-new:6
D4-GH			New KPS/ Install to new Gallery	~95kV/20A x 2; Swi	A-new:7
D4-IJ			New KPS/ Install to new Gallery	~95kV/20A x 2; Swi	A-new:8
D4-KL			New KPS/ Install to new Gallery	~95kV/20A x 2; Swi	A-new:9
D5-AB	A	A-old		90kV/20A x 2; IVR	
D5-CD	B	B(/A-new)	Exchange to new A-type; if possible		A-new:10
D5-EF	A	A-old		90kV/20A x 2; IVR	
D5-GH			New KPS/ Install to new Gallery	~95kV/20A x 2; Swi	A-new:11
			(below two KPS ; not decided for LER or HER)		
D5-IJ			New KPS/ Install to new Gallery; (if used for HER)	~95kV/20A x 2; Switching	A-new:3
D5-KL			New KPS/ Install to new Gallery; (if used for HER)	~95kV/20A x 2; Switching	A-new:4